

Environment Act Licence

Manitoba
Environment and
Workplace Safety
and Health



Licence No. 1277
Issue Date JULY 10, 1989

In accordance with the Manitoba Environment Act (C.C.S.M. c. E125)

THIS LICENCE IS ISSUED TO:

MANITOBA HYDRO, APPLICANT

The following terms and conditions shall be complied with in connection with the construction of a 230 kV transmission line from the Reston area to the Virden area, and the construction of an associated 230/66 kV Station near Virden:

1. The Applicant shall construct the 230 kV transmission line on the preferred route D and the Station at Site 3 in accordance with the construction, operation, and maintenance considerations specified in the Transmission and Stations Engineering and Construction Report entitled "Preferred Reston-Virden 230 kV Transmission Line Route and Station Site Selection", February, 1989.
2. The Applicant shall notify the Historic Resources Branch when construction of the preferred route will occur, so that monitoring of subsurface excavations for the installation of Gulfport Structures may take place at the following locations NE30-9-26W; SW32-9-26W and the road allowance between 30-7-26W and 25-7-27W.
3. The Applicant shall locate towers no closer than 5 metres to the existing Department of Highways right-of-way limits at the following locations:

PTH 2 (NE Cor. Section 12-7-27W)

P.R. 255 (NE Cor. Section 6-9-26W)

P.R. 257 (NE Cor. Section 18-10-26W)

...../2

4. The Applicant shall locate towers no closer than 100 metres from the north limit and 5 metres from the south limit of the right-of-way of PTH 1.
5. The Applicant shall locate the Station a minimum of 100 metres from the edge of the right-of-way of PTH 1.



N.B. Brandson
Director
Environmental Management Services

File: 3051.00