

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and THE MANITOBA WATER SERVICES BOARD,
 Applicant,

WHEREAS

pursuant to the provisions of The Clean Environment Act, The Manitoba Water Services Board filed a proposal with the Department of Mines, Resources and Environmental Management in connection with the operation of a sewage treatment plant to be located in the SE $\frac{1}{4}$ of Section 27-7-17 WPM in the Rural Municipality of Oakland and the Village of Wawanesa, Manitoba, to provide treatment for the sewage from the said Village, with discharge of treated effluent to the Souris River;

AND WHEREAS

in the absence of limits being prescribed by a Regulation under the said Act, the proposal was referred to The Clean Environment Commission for the prescribing of limits;

AND WHEREAS

no representation was made to the Commission by any person who is, or who is likely to be, affected by an Order of the Commission prescribing limits in connection with the said operation;

AND WHEREAS

the Commission considered the proposal on the 25th day of October, 1976;

IT IS HEREBY ORDERED THAT

1. The Applicant shall ensure that the said sewage treatment plant is constructed, maintained and operated in such a manner that on and after the 1st day of September 1977:
 - (a) the release of offensive odours is minimized;
 - (b) the quality of the effluent is such that:
 - (i) the five-day biochemical oxygen demand is not in excess of 30 milligrams per litre; and
 - (ii) the suspended solids content is not in excess of 30 milligrams per litre;

*Assigned to
 W.P.C.
 7701/2
 CBo/ed*


Cont'd . . .

1. (c) the effluent is disinfected prior to discharge to the extent that the fecal coliform count, as indicated by the MPN Index, is not in excess of 200 per 100 millilitres of sample;
 - (d) sludge removed from the plant is disposed of in a manner satisfactory to the Environmental Management Division of the Department of Mines, Resources and Environmental Management.
2. The Applicant shall submit a report on or before the 30th day of September, 1978, to the said Environmental Management Division, giving details of the first year of operation of the said sewage treatment plant and of the measures taken for the disinfection of the effluent, pursuant to the provisions of Sub-clause 1(c) of this Order.

Order No. 642

Dated at the City of Winnipeg

this 5th day of JANUARY, 1977.


Chairman,
The Clean Environment Commission.

C-b-154.1