



Conservation and Water Stewardship

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg, Manitoba R3C 1A5
T 204 945-8321 F 204 945-5229
www.gov.mb.ca/conservation/eal

File: 2471.50

January 22, 2015

Mr. Tom Raine
Chief Administrative Officer
Rural Municipality of Macdonald
Box 100
Sanford MB R0G 2J0
info@rmofmacdonald.com

Dear Mr. Raine:

**Re: Rural Municipality of Macdonald – La Salle Wastewater Treatment Lagoon
Environment Act Licence No. 2674 R**

This is further to liner test results for the new secondary cell of the above facility provided by Jason Bunn of WSP on December 23, 2014. The liner's hydraulic conductivity meets the requirements of Clause 17 of the above licence, and so approval to operate this cell is provided pursuant to Clause 20 of the Licence.

If you have any questions regarding this matter, please contact me at (204) 945-7021 or at Bruce.Webb@gov.mb.ca.

Yours truly,

“original signed by”

Bruce Webb, P. Eng.
Water Development and Control
Assessment Officer

c: Jason Bunn, WSP
Don Labossiere/Donna Smiley, Environmental Compliance and Enforcement Branch
Public Registries