

Boswick, Robert (SD)

From: Boswick, Robert (SD)
Sent: September-29-17 3:15 PM
To: 'Brett McCormac'
Cc: 'cao@rmlabroquerie.ca'; Burland Ross, Siobhan (SD); Markwart, Larry (SD); Paille, Justin (SD); 'Brandon Loewen'; 'Terry Loewen'
Subject: RE: RM of La Broquerie Lagoon - HC Results

Good afternoon Brett,

Receipt of the September 21, 2017 hydraulic conductivity test results of the soil liner material from the recently constructed aeration cells and altered storage cells of the Rural Municipality of La Broquerie aerated wastewater treatment lagoon is acknowledged.

Authorization to operate the recently constructed Aerated Cells No. 1 and No. 2 and the recently altered storage cell of the Rural Municipality of La Broquerie aerated wastewater treatment lagoon in accordance with the limits, terms and conditions of Environment Act Licence No. 1198 RRR is hereby provided.

In accordance with Clause 20 of the Licence it is required that a fence around the lagoon to limit access be installed and maintained.

It is recommended that all proposed rip rap be installed around each aerated cell's inside perimeter dyke slopes prior to transferring liquid to the aerated cells.

It is understood that the inlet, outlet and intercell piping and rip rap associated with this piping have been installed for each cell. It is also understood that the spillway of the wastewater dumping station and rip rap associated with it has been installed.

Finally, please advise our office when commissioning of the aerated and altered storage cells has been completed.

If you have any questions or would like to discuss any of these items, please contact me at 204-945-6030.

Robert Boswick, P.Eng.
Environmental Engineer
Environmental Approvals Branch
Manitoba Sustainable Development
REGULAR MAIL - 160-123 Main Street (BOX 80), Winnipeg MB R3C 1A5
COURIERS - 2nd Floor 123 Main Street, Winnipeg MB R3C 1A5
e-mail: robert.boswick@gov.mb.ca
Ph. (204) 945-6030
Cellular (204) 918-5853
FAX: (204) 945-5229