



Conservation and Water Stewardship

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/conservation/eal

Client File No. 3367.10

January 8, 2016

Mr. Chris Luellman
Chief Administrative Officer
Rural Municipality of Rockwood
Box 902
Stonewall MB R0C 2Z0
Email: info@rockwood.ca

Dear Mr. Luellman:

**Re: Rural Municipality of Rockwood Stony Mountain wastewater treatment lagoon -
wastewater effluent limit for phosphorus in effect January 1, 2016**

As you have been previously notified, your wastewater treatment lagoon is required to meet the 1 mg/L phosphorus limit as of January 1, 2016 in accordance with the Water Quality Standards, Objectives and Guidelines Regulation under *The Water Protection Act*.

The current expansion of your wastewater treatment lagoon for the Rural Municipality of Rockwood operates under Environment Act Licence 3133. Upon the complete construction and commissioning of the facility, Licence 1517 will be rescinded and Clause 29 of Licence 3133 will apply. In the interim, in addition to meeting the 1 mg/L phosphorus limit and in accordance with Clause 1 of Licence 3133, you are hereby required to sample, analyze and report on the total phosphorus content of your wastewater effluent prior to discharging to surface water.

Should you have questions, please contact Bruce Webb at Bruce.Webb@gov.mb.ca or 204-945-7021.

Yours sincerely,

“original signed by”

Tracey Braun, M.Sc.
Director

c: Don Labossiere/Donna Smiley, Environmental Compliance and Enforcement Branch
Nicole Armstrong, Director, Water Science and Management Branch
Bruce Webb, Environmental Approvals Branch
Public Registries