

GLOBAL SUPPLY

Diageo Canada Inc.,
PO Box 2000
19107 Seagram Road
Gimli, Manitoba, Canada
R0C 1B0
Tel: (204) 642-5123
Fax: (204) 642-1640

Notice of Alteration Request

Jennifer Winsor, P. Eng.
Environmental Engineer
Environmental Approvals Branch
Department of Sustainable Development
123 Main St., Ste. 160
Winnipeg, MB R3C 1A5

December 22, 2016

Dear Ms. Winsor,

RE: Diageo Canada Inc. (Diageo) - Gimli Plant- Environment Act License No. 778 – Notice of Alteration – Non-Contact Cooling Water (File 5037.00)

This letter is submitted to Manitoba Sustainable Development as Description of Alteration for our NoA Form regarding non-contact cooling water flow rate.

With the recent completion of the work as approved by Manitoba Conservation under the NoA dated Aug 30/16, which required the installation of a flow meter on the non-contact cooling water discharge, we have verified through system operation that Diageo actual average daily flow rate for the period of observation from October 13 to December 19, 2016 is 800 m3/day with maximum daily flow rates of 1,200 m3/day and not 400 m3/day as original submitted.

By submitting this NoA we are requesting permission for average daily flow rate of non-contact cooling water discharge to be increased from the originally expected 400 m3/day to maximum daily flow rate of 1,400 m3/day and not to exceed this rate of flow for more than seven (7) consecutive days.

Thank you.

Regards,



Oleg Ulyanov
Environment/Power Engineer Manager
Diageo Canada
19107 Seagram Road
Gimli, Manitoba R0C 1B0

cc: Craig Dryburgh, Site Director (Diageo Canada - Gimli)
Leilanie Schmietenknop, Risk Manager (Diageo Canada - Gimli)
Murray Stewart, Distillation Manager (Diageo Canada - Gimli)