

Webb, Bruce (CWS)

To: Steele, Tania (CWS)
Subject: Manitoba Conservation and Water Stewardship - Rainbow Beach Provincial Park Water Treatment PLant Upgrades File: 5695.00

The following information can be placed in the public registries for the above project:

Additional Information Request: No additional information was requested for the project.

Public Comments on the Environment Act Proposal: No public comments were received on the proposal.

Technical Advisory Committee Comments on the Environment Act Proposal: (11 pages)

Manitoba Conservation and Water Stewardship - Environmental Compliance and Enforcement Branch, March 20, 2014
Manitoba Conservation and Water Stewardship – Lands Branch, April 11, 2014 and March 11, 2014
Manitoba Conservation and Water Stewardship – Parks and Protected Spaces Branch, March 10, 2014
Manitoba Conservation and Water Stewardship – Water Science and Management Branch, Groundwater Management Section, March 10, 2014
Manitoba Conservation and Water Stewardship – Office of Drinking Water, April 10, 2014
Manitoba Conservation and Water Stewardship - Water Use Licensing Section, March 10, 2014
Manitoba Conservation and Water Stewardship - Water Control Works and Drainage Licensing Section, March 17, 2014
Manitoba Infrastructure and Transportation – Highway Planning and Design Branch, Environmental Services Section, March 12, 2014
Manitoba Health – Medical Officer of Health, Prairie Mountain Health, March 20, 2014
Office of the Fire Commissioner, April 3, 2014

Bruce.

Webb, Bruce (CWS)

Subject: FW: EAP for review/comments - Rainbow Beach - File: 5695.00

From: Hagenson, Kayla (CWS)
Sent: March-20-14 2:32 PM
To: Webb, Bruce (CWS) *BW*
Subject: RE: EAP for review/comments - Rainbow Beach - File: 5695.00

The Compliance and Enforcement Branch has reviewed the proposal and has no comments or concerns.

Kayla Hagenson, *B.Env.Sc.*
Environment Officer
Conservation and Water Stewardship
Environmental Compliance and Enforcement, Western Region
27-2nd Ave SW
Dauphin, MB R7N 3E5
(204) 622-2316

Webb, Bruce (CWS)

From: Kaita, Adara (CWS) on behalf of +WPG1212 - Conservation_Circulars (CWS)
Sent: April-11-14 3:38 PM
To: Webb, Bruce (CWS) BW
Subject: EA Proposal - CWS - Rainbow Beach Provincial Park WTP Upgrades - File: 5695.00

Hi Bruce,

The Lands Branch has no concerns with the EA proposal.

Thank you for the opportunity to review.

Adara Kaita
Crown Land Programs and Policy Manager
Conservation and Water Stewardship
Box 25, 200 Saulteaux Crescent
Winnipeg, MB R3J 3W3
Cell: (204) 945-6301
F: (204) 948-2197

Webb, Bruce (CWS)

Subject: FW: EAP for review/comments - Rainbow Beach - File: 5695.00

From: Misanchuk, Lorne (CWS)

Sent: March-11-14 9:12 AM

To: Webb, Bruce (CWS)

Subject: RE: EAP for review/comments - Rainbow Beach - File: 5695.00

BW

No concerns to material as presented.

Webb, Bruce (CWS)

Subject: FW: EAP for review/comments - Rainbow Beach - File: 5695.00

From: Kelly, Jason (CWS)

Sent: March-10-14 3:02 PM

To: Webb, Bruce (CWS)

Cc: Harms, Jenny (CWS)

Subject: RE: EAP for review/comments - Rainbow Beach - File: 5695.00

Parks and Protected Spaces Branch has reviewed the proposal filed pursuant to the *Environment Act* for EAP for review/comments - Rainbow Beach - File: 5695.00. The Branch has no comments or concerns to offer.

Jason Kelly, M.N.R.M.
Ecological Reserves and Protected Areas Specialist
Parks and Protected Spaces Branch
Conservation and Water Stewardship
Box 53, 200 Saulteaux Cres
Winnipeg, MB R3J 3W3

Phone: 204-945-4148

Cell:

Fax: 204-945-0012

Email: Jason.Kelly@gov.mb.ca

Webb, Bruce (CWS)

Subject: FW: EAP for review/comments - Rainbow Beach - File: 5695.00

From: Phipps, Graham (CWS)

Sent: March-10-14 12:36 PM

To: Webb, Bruce (CWS) *BW*

Subject: RE: EAP for review/comments - Rainbow Beach - File: 5695.00

Bruce, below are my comments for this application.

"There are a number of wells and testholes for the location of the application in the provincial database including two other wells for the park. To help protect groundwater resources, the other two reported wells or any other wells located in the park that are not being used should be properly sealed. These wells are reported as flowing artesian so a licensed well drilling contractor should be used to properly seal them. A sealed well report should be submitted for each well to the Groundwater Management Section."

Cheers,

Graham

Webb, Bruce (CWS)

From: Stibbard, James (CWS)
Sent: April-10-14 9:38 AM
To: Webb, Bruce (CWS) *BW*
Subject: Re: 5695.00 Mb. Conservation Rainbow Beach Prov. Park New Water Treatment Plant EAP

Bruce,

I reviewed the above noted EAP. This project will require an Application for Permit to Construct or Alter a Public Water System to be submitted to Office of Drinking Water, as per Section 7 of *The Drinking Water Safety Act*.

Apart from this point, Office of Drinking Water has no other concerns with this EAP or the proposed development.

If you have any questions, please call.

Regards,

James Stibbard P. Eng.

Approvals Engineer

Office of Drinking Water

1007 Century Street

Winnipeg MB R3H 0W4

phone: (204) 945-5949

fax: (204) 945-1365

email: James.Stibbard@gov.mb.ca

website: www.manitoba.ca/drinkingwater

Confidentiality Notice: This message, including any attachments, is confidential and may also be privileged and all rights to privilege are expressly claimed and not waived. Any use, dissemination, distribution, copying or disclosure of this message, or any attachments, in whole or in part, by anyone other than the intended recipient, is strictly prohibited.

Webb, Bruce (CWS)

Subject: FW: EAP for review/comments - Rainbow Beach - File: 5695.00

From: Matthews, Rob (CWS)

Sent: March-10-14 11:55 AM

To: Webb, Bruce (CWS)

Subject: RE: EAP for review/comments - Rainbow Beach - File: 5695.00

No concerns.

Webb, Bruce (CWS)

From: Roberts, Dan (CWS)
Sent: March-17-14 2:44 PM
To: Webb, Bruce (CWS) BW
Subject: EAP for review/comments - Rainbow Beach - File: 5695.00

On behalf of the *Water Control Works and Drainage Licensing Section*, there are no concerns.

Dan Roberts

Water Resource Officer
Water Control Works and Drainage Licensing Section
Conservation and Water Stewardship
Box 640, 201 Fourth Ave. S., Swan River, MB R0L 1Z0
Cell: (204) 281-2122, Fax: 734-3733



Infrastructure and Transportation

Highway Planning and Design Branch
Environmental Services Section
1420 - 215 Garry St., Winnipeg, MB R3C 3P3
T (204) 819-4359 F (204) 945-0593

March 12, 2014

Tracey Braun, M. Sc. *BW*
Director, Environmental Approvals Branch
Manitoba Conservation and Water Stewardship
123 Main St., Suite 160
Winnipeg, MB R3C 1A5

RE: Rainbow Beach Provincial Park WTP Upgrades
Client File No. 5695.00

Dear Ms. Braun:

MIT has reviewed the proposal under the Environment Act noted above and we do not have any concern.

Thank you very much for providing us the opportunity to review the proposal.


Sincerely,

Ryan Coulter, M. Sc., P. Eng.
Manager of Environmental Services



PRAIRIE MOUNTAIN HEALTH
SANTÉ PRAIRIE MOUNTAIN

Dr. Amy Frykoda
Medical Officer of Health
P.O. Box 960, 334 -1st St SW, Minnedosa,
Manitoba, R0J 1E0
T 204 867-8730 F 204 867-2239
E amy.frykoda@gov.mb.ca



March 20, 2014

Mr. Bruce Webb *BW*
Manitoba Conservation
Environmental Assessment and Licensing Branch
123 Main Street, Suite 160
Winnipeg, MB, R3C 2A5

Dear Mr. Webb:

Re: Rainbow Beach Provincial Park Water Treatment Plant Upgrades – File: 5695.00

I have reviewed the proposal and have the following comments:

1. Environmental License clauses should ensure the following are addressed:
 - i. adherence to the Guidelines for Canadian Drinking Water Quality
 - ii. adherence to The Public Health Act Manitoba Regulations 330/88R and to applicable regulations in The Drinking Water Safety Act
2. Other issues:
 - i. Will the old WTP be decommissioned? If so, how will this occur?

Sincerely,

“Original Signed By”

Dr. Amy Frykoda, MD, CCFP, MSc
Medical Officer of Health
Prairie Mountain Health

Webb, Bruce (CWS)

Subject: FW: EAP for review/comments - Rainbow Beach - File: 5695.00

From: Kubish, Cheryl (OFC)
Sent: April-03-14 12:49 PM *BW*
To: Webb, Bruce (CWS)
Subject: FW: EAP for review/comments - Rainbow Beach - File: 5695.00

At this time , the Office of the Fire Commissioner (OFC) recommends that the proponent , prior to the construction of the upgraded plant, apply for a building permit from the appropriate authority having jurisdiction (AHJ) for this facility. Based on the size of the facility, the AHJ could be either the local RM or the OFC.

Cheryl Kubish
Administrative Assistant
Office of the Fire Commissioner
508-401 York Avenue
Winnipeg MB R3C 0P8
Phone: 945-3328
Fax: 948-2089

E-Mail address: Cheryl.Kubish@gov.mb.ca