

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg, Manitoba R3C 1A5
T 204 945-8321 F 204 945-5229
www.gov.mb.ca/conservation/eal

CLIENT FILE NO.: 5838.00

August 17, 2016

Jerry Maendel
New Rosedale Holding Co. Ltd.
Box 460
Portage la Prairie MB R0K 3B7

Dear Mr. Maendel:

Enclosed is **Environment Act Licence No. 3198** issued to the **New Rosedale Holding Co. Ltd.** for the construction, operation, and maintenance of the Development being a wastewater collection system, a forcemain, and wastewater treatment lagoon in the Municipality of Glenella-Lansdowne in accordance with the proposal filed under *The Environment Act*.

In addition to the enclosed Licence requirements, please be informed that all other applicable federal, provincial and municipal regulations and by-laws must be complied with. A Notice of Alteration must be filed with the Director for approval prior to any alteration to the Development as licensed.

For further information on the administration and application of the Licence, please feel free to contact Asit Dey, Environmental Engineer, at 204-945-2614.

Pursuant to Section 27 of *The Environment Act*, this licensing decision may be appealed by any person who is affected by the issuance of this Licence to the Minister of Sustainable Development within 30 days of the date of the Licence.

Yours truly,

“original signed by”

Tracey Braun, M.Sc.
Director
Environment Act

c: Don Labossiere, Tim Prawdzik, Peter Crocker, Environmental Compliance and Enforcement
Daniel Burns, Burns Maendel Consulting Ltd.
Public Registries

NOTE: Confirmation of Receipt of this Licence No. 3198 (*by the Licencee only*) is required by the Director of Environmental Approvals. Please acknowledge receipt by signing in the space provided below and faxing a copy (letter only) to the Department by September 1, 2016.

On behalf of New Rosedale Holding Co. Ltd.

Date

LICENCE

Licence No. / Licence n° 3198

Issue Date / Date de délivrance August 17, 2016

In accordance with *The Environment Act* (C.C.S.M. c. E125)
Conformément à *la Loi sur l'environnement* (C.P.L.M. c. E125)

Pursuant to Sections 11(1) and 14(2) / Conformément au Paragraphe 11(1) et 14(2)

THIS LICENCE IS ISSUED TO: / CETTE LICENCE EST DONNÉE À:

NEW ROSEDALE HOLDING CO. LTD.;
"the Licencee"

for the construction, operation, and maintenance of the Development being a wastewater collection system, a forcemain, and wastewater treatment lagoon with a 230-day hydraulic storage capacity of 13,236 cubic metres (57.5 cubic metres per day average), located on NW 16-18-11 WPM in the Municipality of Glenella-Lansdowne, and with discharge of treated effluent from the wastewater treatment lagoon into Alonsa Drain which eventually empties into Jackfish Lake, in accordance with the proposal filed under *The Environment Act* on April 14, 2016 and the Notice of Alteration dated July 20, 2016, and additional information received on August 4, 2016 and subject to the following specifications, limits, terms and conditions:

DEFINITIONS

In this Licence,

"accredited laboratory" means an analytical facility accredited by the Standards Council of Canada (SCC), or accredited by another accrediting agency recognized by Manitoba Sustainable Development to be equivalent to the SCC, or be able to demonstrate, upon request, that it has the quality assurance/quality control (QA/QC) procedures in place equivalent to accreditation based on the international standard ISO/IEC 17025, or otherwise approved by the Director;

"affected area" means a geographical area, excluding the property of the Development;

"approved" means approved by the Director or an assigned Environment Officer in writing;

"ASTM" means the American Society for Testing and Materials;

"base" means the exposed and finished elevation of the bottom of any cell of the wastewater treatment lagoon;

"day" means any 24-hour period;

"Director" means an employee so designated pursuant to *The Environment Act*;

"effluent" means treated wastewater flowing or pumped out of the wastewater treatment lagoon;

"Environment Officer" means an employee so designated pursuant to *The Environment Act*;

"fecal coliform" means aerobic and facultative, Gram-negative, nonspore-forming, rod-shaped bacteria capable of growth at 44.5 °C, and associated with fecal matter of warm-blooded animals;

"five-day biochemical oxygen demand (BOD₅)" means that part of the oxygen demand usually associated with biochemical oxidation of organic matter within 5 days at a temperature of 20°C;

"five-day carbonaceous biochemical oxygen demand (CBOD₅)" means that part of the oxygen demand usually associated with biochemical oxidation of carbonaceous organic matter within five days at a temperature of 20°C, excluding the oxygen demand usually associated with the biochemical oxidation of nitrogenous organic matter;

"flooding" means the flowing of water onto lands, other than waterways, due to the overtopping of a waterway or waterways;

"grab sample" means a quantity of wastewater taken at a given place and time;

"HDPE" means high density polyethylene;

"high water mark" means the line on the interior surface of the primary and secondary cells which is normally reached when the cell is at the maximum allowable liquid level or the line of the exterior of the perimeter dykes which is reached during local flooding;

"hydraulic conductivity" means the quantity of water that will flow through a unit cross-sectional area of a porous material per unit of time under a hydraulic gradient of 1.0;

"influent" means water, wastewater, or other liquid flowing into a wastewater treatment facility;

"in-situ" means on the site;

"low water mark" means the line on the interior surface of the primary and secondary cells which is normally reached when the cell is discharged;

"MPN Index" means the most probable number of coliform organisms in a given volume of wastewater which, in accordance with statistical theory, would yield the observed test result with the greatest frequency;

"odour nuisance" means a continuous or repeated odour, smell or aroma, in an affected area which is offensive, obnoxious, troublesome, annoying, unpleasant or disagreeable to a person:

- a) residing in an affected area;
- b) working in an affected area; or
- c) present at a location in an affected area which is normally open to members of the public;

if the odour, smell or aroma

- d) is the subject of at least 5 written complaints, received by the Director in a form satisfactory to the Director and within a 90-day period, from 5 different persons falling within clauses (a), (b) or (c), who do not live in the same household; or
- e) is the subject of at least one written complaint, received by the Director in a form satisfactory to the Director, from a person falling within clauses (a), (b) or (c) and the Director is of the opinion that if the odour, smell or aroma had occurred in a more densely populated area there would have been at least 5 written complaints received within a 90-day period, from 5 different persons who do not live in the same household;

"primary cell" means the first in a series of cells of the wastewater treatment lagoon system and which is the cell that receives the untreated wastewater;

"record drawings" means engineering drawings complete with all dimensions which indicate all features of the wastewater disposal system as it has actually been built;

"riprap" means small, broken stones or boulders placed compactly or irregularly on dykes or similar embankments for protection of earthen surfaces against wave action or current;

"secondary cell" means a cell of the wastewater treatment lagoon system which is the cell that receives partially treated wastewater from the primary cell;

"sludge" means accumulated solid material containing large amounts of entrained water, which has separated from wastewater during processing;

"sludge solids" means solids in sludge;

"Standard Methods for the Examination of Water and Wastewater" means the most recent edition of Standard Methods for the Examination of Water and Wastewater published jointly by the American Public Health Association, the American Waterworks Association and the Water Environment Federation;

"total coliform" means a group of aerobic and facultative anaerobic, Gram-negative, nonspore-forming, rod-shaped bacteria, that ferment lactose with gas and acid formation within 48 hours at 35° C, and inhabit predominantly the intestines of man or animals, but are occasionally found elsewhere and include the sub-group of fecal coliform bacteria;

"wastewater" means the spent or used water of a community or industry which contains dissolved and suspended matter;

"wastewater collection system" means the sewer and pumping system used for the collection and conveyance of domestic, commercial and industrial wastewater; and

"wastewater treatment lagoon" means the component of this development which consists of an impoundment into which wastewater is discharged for treatment and storage.

GENERAL TERMS AND CONDITIONS

This Section of the Licence contains requirements intended to provide guidance to the Licencee in implementing practices to ensure that the environment is maintained in such a manner as to sustain a high quality of life, including social and economic development, recreation and leisure for present and future Manitobans.

Wastewater Sources

1. The Licencee shall direct all wastewater generated within the New Rosedale Holding Co. Ltd. toward the wastewater treatment lagoon or other approved wastewater treatment facilities.

Future Sampling

2. In addition to any of the limits, terms and conditions specified in this Licence, the Licencee shall, upon the request of the Director:
 - a) sample, monitor, analyze and/or investigate specific areas of concern regarding any segment, component or aspect of pollutant storage, containment, treatment, handling, disposal or emission systems, for such pollutants or ambient quality, aquatic toxicity, leachate characteristics and discharge or emission rates, for such duration and at such frequencies as may be specified;
 - b) determine the environmental impact associated with the release of any pollutant(s) from the Development;
 - c) conduct specific investigations in response to the data gathered during environmental monitoring programs; or
 - d) provide the Director, within such time as may be specified, with such reports, drawings, specifications, analytical data, descriptions of sampling and analytical

procedures being used, bioassay data, flow rate measurements and such other information as may from time to time be requested.

Reporting Format

3. The Licencee shall submit all information required to be provided to the Director or Environment Officer under this Licence, in written and electronic format, in such form (including number of copies), and of such content as may be required by the Director or Environment Officer, and each submission shall be clearly labelled with the Licence Number and Client File Number associated with this Licence.

Respecting Air Emissions

4. The Licencee shall not cause or permit an odour nuisance to be created as a result of the construction, operation or alteration of the Development, and shall take such steps as the Director may require to eliminate or mitigate an odour nuisance.

Equipment Breakdown or Process Upset

5. The Licencee shall, in the case of physical or mechanical equipment breakdown or process upset where such breakdown or process upset results or may result in the release of a pollutant in an amount or concentration, or at a level or rate of release, that causes or may cause a significant adverse effect, immediately report the event by calling Manitoba Sustainable Development's 24-hour environmental accident reporting line at 204-944-4888 (toll-free 1-855-944-4888). The report shall indicate the nature of the event, the time and estimated duration of the event and the reason for the event.
6. The Licencee shall, following the reporting of an event pursuant to Clause 5:
 - a) identify the repairs required to the mechanical equipment;
 - b) undertake all repairs to minimize unauthorized discharges of a pollutant;
 - c) complete the repairs in accordance with any written instructions of the Director; and
 - d) submit a report to the Director about the causes of breakdown and measures taken, within one week of the repairs being done.

Future Studies

7. The Licencee shall actively participate in any future watershed-based management study, plan and/or nutrient reduction program, approved by the Director, for Jackfish Lake, Big Grass River, and Lake Manitoba and associated waterways and watersheds.

Respecting Truck Wash Wastewater

8. The Licencee shall not discharge any truck wash wastewater contaminated with manure into the wastewater treatment lagoon.

SPECIFICATIONS, LIMITS, TERMS AND CONDITIONS

Respecting Construction - General

9. The Licencee shall notify the assigned Environment Officer not less than two weeks prior to beginning construction of the Development. The notification shall include the intended starting date(s) of construction and the name(s) of the contractor(s) responsible for the construction.
10. The Licencee shall:
- a) conduct all ditch related work activities during no flow or dry conditions and not during the April 1 to June 15 fish spawning and incubation period.
 - b) not construct the wastewater treatment lagoon or wastewater collection system during periods of heavy rain;
 - c) place and/or isolate all dredged and construction material where it will not erode into any watercourse;
 - d) implement effective long-term sediment and erosion control measures to prevent soil-laden runoff, and/or silt from entering any watercourse during construction and until vegetation is established;
 - e) routinely inspect all erosion and sediment control structures and immediately complete any necessary maintenance or repair;
 - f) revegetate soil exposed during the construction of the Development with native or introduced grasses or legumes. Native species shall be used to revegetate areas where native species existed prior to construction; and
 - g) use rock that is free of silt and clay for riprap.
11. The Licencee shall, during construction of the Development, operate, maintain and store all materials and equipment in a manner that prevents any deleterious substances (fuel, oil, grease, hydraulic fluids, coolant, paint, uncured concrete and concrete wash water, etc.) from entering the wastewater treatment lagoon, the discharge route and associated watercourses, and have an emergency spill kit for in-water use available on site during construction.
12. The Licencee shall dispose of non-reusable construction debris from the Development at a waste disposal ground operating under the authority of a permit issued pursuant to *Manitoba Regulation 37/2016 respecting Waste Management Facilities*, or any future amendment thereof, or a Licence issued pursuant to *The Environment Act*.

13. The Licencee shall locate all fuel storage and equipment servicing areas established for the construction and operation of the Development a minimum distance of 100 metres from any waterbody, and shall comply with the requirements of *Manitoba Regulation 188/2001* respecting *Storage and Handling of Petroleum Products and Allied Products* or any future amendment thereof.
14. The Licencee shall, during construction and maintenance of the Development, prevent the introduction and spread of foreign aquatic and terrestrial biota by cleaning equipment prior to its delivery to the site of the Development.
15. The Licencee shall install and maintain a fence around the wastewater treatment lagoon to limit access. The fence shall be a minimum of 1.2 meters high and have a locking gate, which shall be locked at all times except to allow access to the wastewater treatment lagoon.

Respecting All-Weather Access Road

16. The Licencee shall construct and maintain an all-weather access road.

Respecting Archeological Sites and/or Heritage Resources

17. The Licencee shall, during construction and operation of the Development:
 - a) contact the Historic Resources Branch of Manitoba Sport, Culture and Heritage if an archaeological site and/or heritage resources are encountered; and
 - b) apply measures to protect heritage resources, as directed by the Historic Resources Branch of Manitoba Sport, Culture and Heritage.

Respecting Construction – HDPE Liner

18. The Licencee shall, prior to the construction of the dykes for the cells of the wastewater treatment lagoon as identified in Schedule “A” attached to this licence, remove all organic material from the area where the wastewater treatment lagoon will be constructed.
19. The Licencee shall construct and maintain a continuous liner, including cover material, underlying the primary and secondary cells of the wastewater treatment lagoon, such that:
 - a) the liner is constructed from HDPE geomembrane;
 - b) the liner has a minimum thickness of 60 mils;
 - c) all sections of the liner are joined by dual track seaming;
 - d) the liner is installed in accordance with ASAE Standard EP340.2 for the Installation of Flexible Membrane Linings;
 - e) the liner is installed to a minimum elevation of 2.8 metres above the base of both the primary and secondary cells;
 - f) non-destructive test methods are used to test the integrity of:

- i) all field seams joining liner sections in accordance with ASTM Standard D 5820-95 (Reapproved 2006); and
 - ii) all other field seams in accordance with ASTM Standard D 4437-99;
 - g) the hydraulic conductivity of the liner does not exceed 3×10^{-9} centimetres per second over the entire surface area of the liner;
 - h) a testing report is prepared and submitted to the assigned Environment Officer for approval within 30 days of commencing the installation of the liner. The report shall include a cover letter with a declaration that the liner is continuous underlying the cells of the wastewater treatment lagoon and that it meets the hydraulic conductivity requirements as stated in Clause 19g). The report shall include a discussion of the tests carried out pursuant to Clause 19f) to determine the liner integrity ; and
 - i) the liner is covered with sand or other granular cover material to a minimum depth of 0.3 metres measured perpendicular to the surface of the liner.
20. The Licencee shall construct and maintain an effective gas relief system under the liners for the primary and secondary cells.
21. The Licencee shall notify the assigned Environment Officer one week prior to commencing the installation of the liner and the gas relief system.
22. The Licencee shall not cover the liner or use the primary and/or secondary cells until receiving the approval of the assigned Environment Officer of the report submitted pursuant to sub-Clause 19 h) of this Licence.
23. The Licencee shall complete the installation of the HDPE liner of the wastewater treatment lagoon between the 15th day of May and the 15th day of October of any year, unless otherwise approved by the Environment Officer.

Respecting Operation - General

24. The Licencee shall obtain and maintain classification of the Development pursuant to *Manitoba Regulation 77/2003* respecting *Water and Wastewater Facility Operators* or any future amendment thereof and maintain compliance with all requirements of the regulation including, but not limited to, the preparation and maintenance of a Table of Organization, Emergency Response Plan and Standard Operating Procedures.
25. The Licencee shall carry out the operation of the Development with individuals properly certified to do so pursuant to *Manitoba Regulation 77/2003* respecting *Water and Wastewater Facility Operators* or any future amendment thereof.

26. The Licencee shall operate and maintain the wastewater treatment lagoon in such a manner that:
- a) the organic loading on the primary cell, as indicated by the five-day biochemical oxygen demand, is not in excess of 56 kilograms per hectare per day;
 - b) the depth of liquid in the primary cell and the secondary cells does not exceed 1.5 metres; and
 - c) a 1.0 metre freeboard is maintained in the primary cell and the secondary cells at all times.

Respecting Operation – Wastewater Treatment Lagoon

27. The Licencee shall not discharge effluent from the wastewater treatment lagoon:
- a) where the organic content of the effluent, as indicated by the five day carbonaceous biochemical oxygen demand, is in excess of 25 milligrams per litre;
 - b) where the total suspended solids content of the effluent is in excess of 25 milligrams per litre, unless the exceedance is caused by algae;
 - c) where the fecal coliform content of the effluent, as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample;
 - d) where the unionized ammonia content of the effluent is in excess of 1.25 milligrams per litre, expressed as nitrogen (N), at $15^{\circ}\text{C} \pm 1^{\circ}\text{C}$;
 - e) between the 1st day of November of any year and the 15th day of June of the following year;
 - f) when flooding from any cause is occurring along the effluent drainage route; or
 - g) when the discharge of effluent would cause or contribute to flooding in or along the effluent drainage route.
28. The Licencee shall discharge the wastewater treatment lagoon over at least a two-week period, while accelerating discharge as necessary to maintain normal operation of the wastewater treatment lagoon.

Respecting Disinfection – General

29. The Licencee shall, when chlorine is used as a disinfecting agent:
- a) notify the Director in advance;
 - b) dechlorinate effluent prior to discharge;
 - c) obtain grab samples prior to and daily during the discharge period and have them analyzed for total residual chlorine; and
 - d) not discharge effluent where the concentration of the total residual chlorine is in excess of 0.02 milligrams per litre.

Respecting Maintenance

30. The Licencee shall, if in the opinion of the Director or Environment Officer, significant erosion of the interior surfaces of the dykes occurs, repair the dyke and install riprap as

necessary. The riprap shall be placed on the interior dyke surfaces from 0.6 metres above the high water mark to the bottom of the dykes to protect the dykes from wave action.

31. The Licencee shall provide and maintain a grass cover on the dykes of the wastewater treatment lagoon and shall regulate the growth of the vegetation so that the height of the vegetation does not exceed 0.3 metres on all dykes.
32. The Licencee shall annually remove by mechanical methods all reeds, rushes and trees located above the low water mark in every cell of the wastewater treatment lagoon.
33. The Licencee shall implement an ongoing program to remove burrowing animals from the site of the wastewater treatment lagoon.

MONITORING AND REPORTING

General

34. The Licencee shall, unless otherwise specified in this Licence:
 - a) carry out all preservations and analyses on liquid samples in accordance with the methods prescribed in Standard Methods for the Examination of Water and Wastewater or in accordance with an equivalent preservation and analytical methodology approved by the Director;
 - b) carry out all sampling of, and preservation and analyses on, soil, compost, and air samples in accordance with methodologies approved by the Director;
 - c) have all analytical determinations undertaken by an accredited laboratory; and
 - d) report the results to the Director, in writing and in an electronic format acceptable to the Director, within 60 days of the samples being taken.

Respecting Monitoring

35. The Licencee shall, prior to each effluent discharge campaign, obtain grab samples of the treated wastewater and have them analyzed for:
 - a) the organic content as indicated by the five-day carbonaceous biochemical oxygen demand and expressed as milligrams per litre;
 - b) the total suspended solids content expressed as milligrams per litre;
 - c) the fecal coliform content as indicated by the MPN index and expressed as MPN per 100 millilitres per sample;
 - d) the total phosphorus content expressed as milligrams per litre; and
 - e) the unionized ammonia nitrogen expressed as milligrams per litre.

Respecting Operating Depth and Freeboard Non-Compliance Events

36. The Licencee shall immediately notify the Director each time the operating depth of any cell of the wastewater treatment lagoon does not comply with the maximum operating depth and minimum freeboard requirements for that cell as specified in Clause 26 of this Licence.
37. The Licencee shall, if reporting is required pursuant to Clause 36 of this Licence in two consecutive years:
- a) engage the services of a qualified consultant, acceptable to the Director, to undertake an investigation of the wastewater treatment lagoon and related infrastructure, to determine the ability or inability of the existing system to meet the hydraulic loading capacity of the community. The investigation shall include but not be necessarily limited to:
 - i) diagnosis of the cause(s) of the recent exceedances of maximum operating depth;
 - ii) sources of infiltration into the wastewater system including the municipal infrastructure;
 - iii) current hydraulic loading of the system;
 - iv) lack of storage capacity due to sludge build-up within existing cells;
 - v) the organic loading on the primary cell in terms of the five day biochemical oxygen demand; and
 - vi) operating procedures;
 - b) provide to the Director, within four months of the notification given pursuant to Clause 36 of this Licence, an engineering report describing in detail the results and observations concluded by virtue of the investigation; and
 - c) provide to the Director, within four months of the report provided pursuant to sub-Clause b) of this section, a remedial action plan in the form of a detailed engineering report describing recommended modifications, repairs or upgrading works to overcome excessive hydraulic loading of the system.

Respecting Records Maintenance and Reporting

38. The Licencee shall during each year maintain the following records and retain them for a minimum period of five calendar years:
- a) reports of visual inspections conducted at a minimum of once per month;
 - b) wastewater sample dates;
 - c) original copies of laboratory analytical results of the sampled wastewater;
 - d) a summary of laboratory analytical results;
 - e) effluent discharge dates;
 - f) estimated effluent discharge volumes;
 - g) maintenance and repairs; and
 - h) a summary of any sanitary sewer overflows.

39. The Licencee shall submit an annual report to the Environment Officer by February 28 of the following year including all records required by Clause 38 of this Licence.

Respecting Initial Characterization

40. The Licencee shall, during the first year of operation of the Development following the issuance of this licence that a discharge must occur, obtain and analyze grab samples of the effluent during each effluent discharge campaign and report the results of the analysis in accordance with Schedule "B" attached to this Licence.

Respecting Record Drawings

41. The Licencee shall:
- a) prepare "record drawings" for the Development and shall label the drawings "record drawings"; and
 - b) provide to the Director, within four months of the approved commissioning of the Development, two sets of "record drawings" of the Development.

REVIEW AND REVOCATION

- A. If, in the opinion of the Director, the Licencee has exceeded or is exceeding or has or is failing to meet the specifications, limits, terms, or conditions set out in this Licence, the Director may, temporarily or permanently, revoke this Licence.
- B. If the Licencee has not commenced construction of the Development within three years of the date of this Licence, the Licence is revoked.
- C. If, in the opinion of the Director, new evidence warrants a change in the specifications, limits, terms or conditions of this Licence, the Director may require the filing of a new proposal pursuant to Section 11 of *The Environment Act*.


"original signed by"

Tracey Braun, M.Sc.
Director
Environment Act

Schedule "A" to Environment Act Licence No. 3198

Cell Identifications Relative to Clause 18

ABATTOIR
TOTAL WASHWATER: 109.3m³
TOTAL BLOOD: 0.655m³
ORGANIC LOADING: 0.2kg BOD5 / L
ORGANIC LOADING / AREA: 56 kg BOD5



Not to Scale

Schedule "B" to Environment Act Licence No. 3198

Initial Characterization of Wastewater Pursuant to Clause 40

Facility Size: Very small (less than 500 m³/day)

Facility Type: Facultative wastewater treatment lagoon – intermittent discharge

Effluent Sampling:

During the first year of operation, for all discharge events:

1. Obtain a representative grab sample of the discharging effluent near the beginning of the discharge period and near the end of the discharge period (i.e., two samples for each discharge event); and
2. Determine the temperature of each sample at the time of sampling.

Effluent Analysis:

1. For each grab sample, have the grab sample analysed for:
 - a) the organic content as indicated by the five-day biochemical oxygen demand and expressed as milligrams per litre;
 - b) the organic content as indicated by the five-day carbonaceous biochemical oxygen demand and expressed as milligrams per litre;
 - c) the total suspended solids content expressed as milligrams per litre;
 - d) the *Escherichia coli* (*E. Coli*) content as indicated by the MPN index and expressed as MPN per 100 millilitres per sample;
 - e) the fecal coliform content as indicated by the MPN index and expressed as MPN per 100 millilitres per sample;
 - f) the total coliform content as indicated by the MPN index and expressed as MPN per 100 millilitres per sample;
 - g) if chlorine was used as a disinfecting agent, total residual chlorine expressed as milligrams per litre;
 - h) total ammonia nitrogen expressed as milligrams per litre;
 - i) nitrate-nitrite nitrogen expressed as milligrams per litre;
 - j) total Kjeldahl nitrogen (TKN) expressed as milligrams per litre;
 - k) dissolved phosphorus expressed as milligrams per litre;
 - l) total phosphorus expressed as milligrams per litre; and
 - m) pH.

Effluent Reporting:

1. For each grab sample, report the results to the Director, in writing or in an electronic format acceptable to the Director within 60 days of the sampling date. The report shall include the sampling date, sample temperature, the dates of the effluent discharge, and copies of the laboratory analytical results of the sampled effluent.